



NOTES:

- 1) ALL FLASHINGS MUST BE A MIN. HEIGHT OF 8" ABOVE THE FIELD MEMBRANE.
- 2) EXISTING COUNTERFLASHING IS ACCEPTABLE IF ABOVE MAXIMUM FLOOD LEVEL AND METAL IS IN GOOD CONDITION.
- 3) FUNCTIONAL WEEP HOLE MUST NOT BE BLOCKED
- 4) ALL FLASHING MEMBRANE THAT IS INSTALLED HIGHER THAN 18" VERTICAL MUST BE ADHERED TO SUBSTRATE.
- 5) IF FLASHING HEIGHT IS HIGHER THAN 48" PLEASE REFER TO FLEX DETAIL 2.40.

| | | |
|-----------------------------------|--|-----------------|
| TITLE | WALL FLASHING CUT IN REGLET | |
| NAME | DETAIL NO. 2.20 | |
| DRAWN BY: | SK | DATE: 1/2016 |
| APPLICABLE TO ALL FLEX | | |
| MECHANICALLY FASTENED SYSTEMS | | |
| FLEX MEMBRANE INTERNATIONAL | 2670 LEISCZ'S BRIDGE RD. LEESPORT, PA 19533 800-969-0108 FlexRoofingSystems.com | |