



NOTES:

1) ALL FLASHINGS MUST BE A MIN. HEIGHT OF 8" ABOVE THE FIELD MEMBRANE.

2) ALL FLASHING MEMBRANE THAT IS INSTALLED HIGHER THAN 18" VERTICAL MUST BE ADHERED TO SUBSTRATE.

3) FLEX CUT EDGE SEALANT IS REQUIRED AT ALL NON FACTORY CUT EDGES

TITLE	
CURB FLASHING-NON REMOVABLE	
NAME	
DETAIL NO. 3.31	
DRAWN BY:	DATE:
SK	5/2017
APPLICABLE TO ALL FLEX TPO	
ADHERED ROOFING SYSTEMS	
FLEX MEMBRANE INTERNATIONAL	2670 LEISCZ'S BRIDGE RD. LEESPORT, PA 19533 800-969-0108 FlexRoofingSystems.com