



NOTES:

1. WHEN FLEX EXPANSION JOINT IS USED, WIDTH OF JOINT SHALL BE A MINIMUM OF 3/4" (19 mm) AND SHALL NOT EXCEED 2" (50 mm).
2. APPROXIMATELY 1/8" (3 mm) DIAMETER BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF FLEX TPO ADHERED MEMBRANE.

TITLE		WALL EXPANSION JOINT	
NAME		DETAIL NO. 3.20	
DRAWN BY:	SK	DATE:	8/2012
APPLICABLE TO ALL FLEX			
TPO ADHERED SYSTEMS			
FLEX MEMBRANE INTERNATIONAL		2670 LEISCZ'S BRIDGE RD. LEESPORT, PA 19533 800-969-0108 FlexRoofingSystems.com	