



NOTES:

REFER TO MANUFACTURES APPROVALS FOR MEMBRANE FASTENING CRITERIA, MEMBRANE FASTENING CRITERIA” FOR PROPER FASTENERS, PLATES AND FASTENING DENSITY. IF A FACTORY MUTUAL RATING IS REQUIRED, REFER TO FLEX FM APPROVAL GUIDE.

1. POSITION SEAM FASTENING PLATES BEYOND NON-REINFORCED ENCAPSULATED EDGE.
2. APPROXIMATELY 1/8” (3 mm) DIAMETER BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF FLEX TPO REINFORCED MEMBRANE.

TITLE	
LAP CROSS SECTION	
NAME	
DETAIL NO. 2.30	
DRAWN BY:	DATE:
SK	8/2012
APPLICABLE TO ALL FLEX TPO	
MECHANICALLY FASTENED SYSTEMS	
FLEX MEMBRANE INTERNATIONAL	2670 LEISCZS BRIDGE RD LEESPORT, PA 19533 800-969-0108 FlexRoofingSystems.com