

EXTEND FLASHING OVER JOINT BETWEEN BLOCKING AND WALL 1" MIN.

8" WIDE CONCEALED SPLICE PLATE AT EACH JOINT

12" WIDE 20 GA GALV. ANCHOR CLIPS
LOCATE ANCHOR CLIPS 4'-0" O.C.

#9 X 1 1/2 STAINLESS STEEL FASTENERS

COPING COVER 12'-0" LENGTHS

FLEX BONDING ADHESIVE

FLEX MF/R FLASHING MEMBRANE FULLY ADHERED TO SUBSTRATE WITH FLEX BONDING ADHESIVE

FLEX PLATE AND FASTENER

HEAT WELDED 2" SEAM

FLEX MFR MEMBRANE ATTACHED

DECK

APPROVED SUBSTRATE

1) ALL FLASHINGS MUST BE A MIN. HEIGHT OF 8" ABOVE THE FIELD MEMBRANE.

2) ALL FLASHING MEMBRANE THAT IS INSTALLED HIGHER THAN 18" VERTICAL MUST BE ADHERED TO SUBSTRATE.

3) IF FLASHING HEIGHT IS HIGHER THAN 48" PLEASE REFER TO FLEX DETAIL 2.40.

4) FLEX TPO: FLEX TPO CUT EDGE SEALANT IS REQUIRED ON ALL NON FACTORY CUT EDGES OF FLEX TPO

TITLE	
PARAPET WALL W/ FLEX CAP COPING	
NAME	
DETAIL NO. 2.30	
DRAWN BY:	DATE:
SK	2/2018
APPLICABLE TO ALL FLEX	
MECHANICALLY ATTACHED SYSTEMS	
FLEX MEMBRANE INTERNATIONAL	2670 LEISCZ'S BRIDGE RD. LEESPORT, PA 19533 800-969-0108 FlexRoofingSystems.com